· From

The Head

Department of Microbiology

PAU, Ludhiana.

To

The Principal

Green Land Convent School

Phase-II, Dugri Ludhiana

Memo. No. 113 Dated: 06/01/23

Subject:

Bacteriological quality of drinking water (IS-10500:1991. BIS New Delhi).

Reference is made to your letter No. nil dated 02.01.2023 regarding sample of water for bacteriological analysis.

REPORT

S. No.	Source	Colifor	m organisms	Faecal Coliform / E. coli Detected / Not detected
		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water sample	Absent	Accessory or consequently all places and an experience of the consequently of the consequently and the consequently all places are consequently and the consequently are consequently as a consequently as a consequently and the consequently are consequently as a con	Not Detected

INFERENCE	*
Bacteriologically safe	:- 01
*Bacteriologically not safe	:- níl

Technician
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

Incharge

Water Testing Lab

Department of Microbiology

PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

Head Department of Microbiology

*Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores

For Sant Kirpal Vidyak Mission (Regd.)

Ruelhie

Principal

Green Land Convent School Phase-II Dugri, Ludhiana.